



**CERTIFIKAT  
O USKLADENOSTI**  
CERTIFICATE OF CONFORMITY

Br.  
No. T 15 007X

Proizvod Product	POTOPNA PUMPA TIP: BS 2125.690
Osnovni podaci o proizvodu Principal characteristics of the product	Zaštita: I M2 EEx d I; Napon: 500 V; Maksimalna snaga: 9,4 kW/11,1 kW; Broj okretaja: 2895 o/min/2865 o/min; Mehanička zaštita: IP68.
Proizvođač / Isporučilac Manufacturer / Supplier	Xylem Water Solutions Manufacturing AB, Emmaboda-Sweden
Podnosilac zahtjeva Applicant	Xylem Water Solutions Sweden AB, Sundbyberg-Sweden
Izveštaj o ispitivanju br. The test report No.	SP 02ATEX0102X od 04.10.2002 godine te pregled proizvodnje i kontrole uređaja kod proizvođača.
Ispitna laboratorija Testing laboratory	Laboratorija za protiveksplozijsku zaštitu SP Swedish National Testing and Research Institute Certification-Boras, Sweden.
Tijelo za certificiranje Certification Body	Ex komisija BiH, Rješenje 01/96-2616 od 1996.09.02.
Važi do Valid until	2018-10-20.

**Potvrđuje se da je ispitani uzorak proizvoda u skladu sa zahtjevima slijedećih propisa i standarda**

**It is certified that the tested sample of the product is in the conformity with requirements of the following regulations and standards**

Naredba o obaveznom atestiranju protiveksplozijski zaštićenih električnih uređaja namjenjenih za upotrebu u ugroženim prostorima, Sl. list SFRJ br. 25/81 i standardi  
BAS EN 60079-0:2009, BAS EN 60079-1:2004, BAS EN 60079-7:2006,  
BAS EN 13463-1:2005, BAS EN 13463-3:2008 i BAS EN 1127-2:2002.

Datum izdavanja  
Date of Issue 2015-10-20.



Potpis ovlaštene osobe  
Authorized Signature  
*[Handwritten signature]*

